

**Wilkes Street - TOWN OF BATH SIDEWALK EVALUATION**

Street	Sidewalk Map No.	Corner Map Letter	Evaluated Condition Code	Condition Found (Missing Sections; warped; steps/drops; patches; <4 ft wide)	Complies w/ADA Stds?	Notes
	1, 2, 3 etc	A, B, C etc	G-Y-R	MS-W-S/D-P-<4'	Ramps/Material	Status in Streetscapes Plans
		<b>A</b>	<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase 3
<b>Wilkes St</b>	<b>1</b>		<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase
		<b>C</b>	<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase
		<b>B</b>	<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase 3
<b>Wilkes St</b>	<b>2</b>		<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase
		<b>D</b>	<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase
		<b>E</b>	<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase
<b>Wilkes St</b>	<b>3</b>		<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase
		<b>G</b>	<b>G</b>	Good Condition	<b>Yes</b>	Completed in Streetscapes Phase
		<b>F</b>	<b>R</b>	End ramps match to street level; no ADA provisions	<b>No</b>	Planned for review in Phase 4
<b>Wilkes St</b>	<b>4</b>		<b>G</b>	Generally OK condition		Planned for review in Phase 4
		<b>H</b>	<b>R</b>	No end ramp treatment, sidewalk ends at curb height		Planned for review in Phase 4
		<b>I</b>	<b>R</b>	No sidewalk or corner treatment in this block	<b>No</b>	Planned for review in Phase 4
<b>Wilkes St</b>	<b>5</b>		<b>R</b>	No sidewalk or corner treatment in this block	<b>No</b>	Planned for review in Phase 4
		<b>K</b>	<b>R</b>	No sidewalk or corner treatment in this block	<b>No</b>	Planned for review in Phase 4
		<b>J</b>	<b>R</b>	No corner treatment; corner is gravel/stone	<b>No</b>	Planned for review in Phase 4
<b>Wilkes St</b>	<b>6</b>		<b>R</b>	Sidewalk badly broken and cracked, many puddles	<b>No</b>	Planned for review in Phase 4
		<b>L</b>	<b>R</b>	Corner has no treatment, gravel area only to Union St.	<b>No</b>	Planned for review in Phase 4

**Wilkes Street - TOWN OF BATH SIDEWALK EVALUATION**


Street	Sidewalk Map No.	Corner Map Letter	Evaluated Condition Code	Condition Found (Missing Sections; warped; steps/drops; patches; <4 ft wide)	Complies w/ADA Stds?	Notes
	1, 2, 3 etc	A, B, C etc	G-Y-R	MS-W-S/D-P-<4'	Ramps/Material	Status in Streetscapes Plans
		M	R	No sidewalk or corner treatment in this area; Parking for Town Building	No	
Wilkes St	7		R	Existing & narrow sidewalk starts about half-way to Kent St	No	
		O	R	Sidewalk ends near Kent St	No	
		N	R	Parking Lots and access lanes take the place of any sidewalk	No	
Wilkes St	8		R	Narrow Sidewalk begins after church parking lot	No	
		P	R	Sidewalk ends near Kent St	No	
Wilkes St			No Sidewalks	Past Kent St there are no Sidewalks on either side of Wilkes St	No	

**Wilkes Street - TOWN OF BATH SIDEWALK EVALUATION**

Street	Sidewalk Map No.	Corner Map Letter	Evaluated Condition Code	Condition Found (Missing Sections; warped; steps/drops; patches; <4 ft wide)	Complies w/ADA Stds?	Notes
	1, 2, 3 etc	A, B, C etc	G-Y-R	MS-W/S/D-P-<4'	Ramps/Material	Status in Streetscapes Plans

**Identification & Coding of Sidewalks & Corners**

**Sidewalk Assessment by Streets & Blocks  
Wilkes St (Fairfax to Legion St)**




**Wilkes Street - TOWN OF BATH SIDEWALK EVALUATION**

Street	Sidewalk Map No.	Corner Map Letter	Evaluated Condition Code	Condition Found (Missing Sections; warped; steps/drops; patches; <4 ft wide)	Complies w/ADA Stds?	Notes
	1, 2, 3 etc	A, B, C etc	G-Y-R	MS-W-S/D-P-<4'	Ramps/Material	Status in Streetscapes Plans

**Color Coding of Results**

**Sidewalk Assessment by Streets & Blocks  
Wilkes St (Fairfax to Legion St)**





- Key:
- Green – Near-new/new condition; meets ADA Criteria (also completed/Streetscapes Phase)
  - Yellow – SWV & Corner with some patches/steps/erosion; serviceable; not fully up to ADA Criteria
  - Red – Poor condition, materials; major patches, steps and drops; not ADA compliant



**Wilkes Street - TOWN OF BATH SIDEWALK EVALUATION**

Street	Sidewalk Map No.	Corner Map Letter	Evaluated Condition Code	Condition Found (Missing Sections; warped; steps/drops; patches; <4 ft wide)	Complies w/ADA Stds?	Notes
	1, 2, 3 etc	A, B, C etc	G-Y-R	MS-W-S/D-P-<4'	Ramps/Material	Status in Streetscapes Plans

**PHOTOS OF SPECIFIC AREAS**



**Wilkes Street - TOWN OF BATH SIDEWALK EVALUATION**

Street	Sidewalk Map No.	Corner Map Letter	Evaluated Condition Code	Condition Found (Missing Sections; warped; steps/drops; patches; <4 ft wide)	Complies w/ADA Stds?	Notes
	1, 2, 3 etc	A, B, C etc	G-Y-R	MS-W-S/D-P-<4'	Ramps/Material	Status in Streetscapes Plans

**PHOTOS OF SPECIFIC AREAS**

