## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO COMPLETE CORRECTIVE ACTIONS

BERKELEY SPRINGS CITY OF, WV3303301

Our water system violated State drinking water requirement. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation (See table below).

An on-site evaluation of our system is conducted on a regular basis. Results of the evaluation show significant deficiencies in our water system which must be addressed to the Office of Environmental Health Services- District Office. We did not correct these deficiencies by the required date and are therefore in violation.

## What should I do?

There is nothing you need to do at this time.

Required Corrective Action	Corrective Action Required by:
Failure to correct 2 significant deficiencies	June 29, 2022

What happened? What is being done? (Describe corrective action)

## Deficiency #1 - Treatment plant (TP 001) operator coverage; The WVBPH Legislative Rules (Title 64, Series 4) requires Class II or higher PWS to have a Class II operator present at all times water is being treated unless a waiver from the Director has been granted. Corrective Action: A waiver has been submitted to the state. We are awaiting the granting of said waiver. Deficiency#2 - Distribution System(DS001) No Cross - Connection Program: Corrective Action: Cross connection program is in the process of being implemented.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by **BERKELEY SPRINGS CITY OF** 

(Mailing Address)

State Water System ID# WV3303301

or 271 Wilkes Street, Berkeley Springs WV 25411

Date	Distributed	9-29-2022	